

ASSAM CANCER CARE FOUNDATION (ACCF)
3rd floor, V.K. Trade Centre, G.S. Road, Opp. Down-town Hospital,
Guwahati – 781022, Assam Ph: +91-90852 02020
E: procurement@accf.in | W: www.assamcancercarefoundation.org

REQUEST FOR PROPOSAL (RFP)

FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING of “Digital Water Level Recorder with Telemetry System and Flowmeter with Telemetry system for Assam Cancer Care Hospitals”

Tender Ref No. RFP No: ACCF/CGWA/2023-24/73 DTD 22.12.2023

CORRIGENDUM-1

Date: 4th January 2024

Query Resolution

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	Justification / reference for change	ACCF Clarification / Amendment
1	RFP No: ACCF/CGWA/2023-24/73 Pg No: 41	Supply of GSM based Electromagnetic Flow meter - (80 NB), Make- CGWA approved TECHNICAL SPECIFICATION Size – 15 to 350 NB Liner – PTFE (Teflon) Media – Liquid Display – Standard 16*2 LCD Type – Integral/Remote (upto 10m cable length	As per CGWA Approval documents. Both Electromagnetic & Ultrasonic Telemetric Flowmeters are approved. Kindly confirm if we can participate with Ultrasonic Telemetric Water Flow Meter.	NA	Accepted for the ultrasonic telemeter-type flow meter, but the prices should align with the electromagnetic flow meter to avoid incurring additional expenses for user resulting from a shift in meter technology. Bidder can quote most economic option out of both Electromagnetic & Ultrasonic Telemetric Flowmeters.
2	RFP No: ACCF/CGWA/2023-24/73 Pg No: 41	Supply of GSM based Electromagnetic Flow meter - (80 NB), Make- CGWA approved TECHNICAL	Is there a specific approved make list for quoting	NA	No specific brand preferences, but bidder need to prove that quoted

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	Justification / reference for change	ACCF Clarification / Amendment
		SPECIFICATION Size – 15 to 350 NB Liner – PTFE (Teflon) Media – Liquid Display – Standard 16*2 LCD Type – Integral/Remote (upto 10 m cable length)			make is accepted/Approved by CGWA.
3	RFP No: ACCF/CGWA/2023-24/73 Pg No: 41	Supply of electrical work such as cables, switch, board, etc with all accessories complete as directed and specified	Our Telemetric Ultrasonic Flowmeters are Battery Operated, with a life of 3 to 5 years*. Therefore, no cabling works are required. Our technology is CGWA approved, therefore, are we allowed to participate in the mentioned tender	NA	Accepted you can provide ultrasonic flow meter
4	RFP No: ACCF/CGWA/2023-24/73 Pg No: 41	BOQ: 2. SITC of GSM-based Piezometer (Online Telemetry System) - 50 Mtr cable length complete with all accessories Make - CGWA approved 3. SITC of Software Application and SIM Card (Online Telemetry System - Flowmeter) complete with all accessories	We wish to participate in the Item SI No as per BoQ in 2 & 3. Therefore, our query - Is Part Tendering Participation Allowed?	NA	Not acceptable, bidder has to quote for the system with complete Installation and commissioning.
5	RFP No: ACCF/CGWA/2023-24/73		Please confirm the nature of liquid if it is water or any other liquid	NA	Nature of liquid is water Only

Sd/-
COO, ACCF