

ASSAM CANCER CARE FOUNDATION
3rd floor, V.K. Trade Centre, G.S. Road, Opp. Down Town Hospital,
Guwahati – 781022, Assam Ph: +91-90852 02020
E: procurement@accf.in | W: www.assamcancercarefoundation.org

Tender Ref: ACCF/ELE/2023-24/64

Tender Details: Request for proposal for Electrical safety audit of Assam Cancer Care Foundation's 7 hospitals

Corrigendum-1

Date: 23-June-2023

SL No.	BID clause no.	Query raised/ Request for Changes	Clarification(s)/Amendment(s)
1	Additional information	Requested to provide us SLD of electrical layout of the hospitals to be audited. The said details would enable bidder to quantify the number of man-days required for the audit.	SLD drawings are uploaded on website - www.assamcancercarefoundation.org under EOI and tender section. SLD drawing for Barpeta, Dibrugarh are uploaded, Other hospitals are L3 prototype hence one site SLD drawing is uploaded.
2	Additional Clarification	1. Whether earth pit test needs to be carried out by the auditor and whether auditor is supposed to capture the values of earth resistance (IR value)	Verifying the earth pit values according to the standards, without the need for separate tests.
3	Addition in scope of work	As discussed, during the pre-bid meeting thermography test to be carried for LT panels. Please confirm, whether it would be standard condition in the scope of work.	Added in as 3.14 in scope of work <ul style="list-style-type: none"> To Conduct thermography tests for LT panels.
4	Addition in scope of work	1. As discussed, during the pre-bid meeting, If possible, Megger test for individual circuits inside DB shall be carried out on sample basis.	Added in as 3.15 in scope of work <ul style="list-style-type: none"> To Perform megger tests on individual circuits inside the distribution board on a random basis.
	Addition information	1. Required As Built drawings to be made available on site at the time of audit . (Expected)	Available drawings will be shared

SL No.	BID clause no.	Query raised/ Request for Changes	Clarification(s)/Amendment(s)
	Addition information	2. Required Technical representative to be present while on Audit for Coordination & Witness	Site engineer or maintenance engineer will be available for coordination as per prefixed schedule.

Rest of the tender terms and conditions remains the same.

-Sd-
Head Procurement, ACCF