

ASSAM CANCER CARE FOUNDATION (ACCF)
3rd floor, V.K. Trade Centre, G.S. Road, Opp. Down-town Hospital,
Guwahati – 781022, Assam Ph: +91-90852 02020
E: procurement@accf.in | W: www.assamcancercarefoundation.org

REQUEST FOR PROPOSAL (RFP)

Supply, installation, testing and commissioning of operation theatre works at Barpeta, Silchar and Dibrugarh

Tender Ref No. ACCF/OT/2025/94 Date:28/02/2025

CORRIGENDUM-1

Date: 17-03-2025

Pre-Bid Query Resolution

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
1	BoQ Barpeta Sl. No. 1	Antimicrobial Coating on Wall. Supply and Installation of Antibacterial Paint on Walls	Antimicrobial Coating on Wall & Ceiling with Riser Covering. Supply and installation of Antibacterial Paint on Walls & Ceiling with Riser Covering.	No Change
2	Point No. 4.6: Key Points	Completion of installation and commissioning: 60 Days from date of issuance of work order.	Completion of installation and commissioning: 90 Days from date of issuance of work order.	Only a 60-day period will be followed, as there are no items in our BOQ that require a longer lead time
3	Tender Terms	Due Date - 19.03.2025, 1500 hrs	Kindly extend due date	Separate amendment will be issued

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
4	BoQ Barpeta Sl. No. 2	Powder Coated False Ceiling-2x2: Supply and Installation of GI powder- coated ceiling tiles of 600x 600mm with main & cross grid and required accessories - Armstrong make	PPGI Ceiling Panels Double Skin 40/50 mm. The clean room ceiling fabricated double skin by 0.50 mm PPGI sheet thickness to form modular panels, facing sides finished with PPGI Sheet, the thickness of the panel will be 40/50 mm with 40 Kg/m3 PUFF density PUFF insulated, joints sealed with silicon sealant. The panels shall be anchored to the slab with threaded rod.	No Change
5	BoQ Barpeta Sl. No. 13	SITC of Aluminium Ducting with Insulation Inside OT with Exhaust Air Grill: Aluminium Ducting with Nitrile Insulation inside OT i.e. Supply & Return Air Ducts made out of Aluminium Sheet ducting 22 Swg. along with Nitrile insulation with 13mm thickness on supply ducts and 9mm on Return Ducts with required accessories and connections with the plenum. 4 numbers return duct duct-integrated aluminium powder-coated exhaust grills to be considered	SITC of PPGI Ducting with Insulation Inside OT with Exhaust Air Grill: PPGI Ducting with Nitrile Insulation inside OT i.e. Supply & Return Air Ducts made out of PPGI Sheet ducting 22Swg. Along with Nitrile insulation with 13mm thickness on supply ducts and 9mm on Return Ducts with required accessories and connections with the plenum. 4 numbers return duct duct-integrated aluminium powder-coated exhaust grills to be considered	BOQ to be followed. No change.

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
6	BoQ Silchar Sl. No. 12	SITC of Aluminium Ducting with Insulation Inside OT with Exhaust Air Grill: Aluminium Ducting with Nitrile Insulation inside OT i.e. Supply & Return Air Ducts made out of Aluminium Sheet ducting 22 Swg. along with Nitrile insulation with 13mm thickness on supply ducts and 9mm on Return Ducts with required accessories and connections with the plenum. 4 numbers return duct duct-integrated aluminium powder-coated exhaust grills to be considered	SITC of PPGI Ducting with Insulation Inside OT with Exhaust Air Grill: PPGI Ducting with Nitrile Insulation inside OT i.e. Supply & Return Air Ducts made out of PPGI Sheet ducting 22Swg. Along with Nitrile insulation with 13mm thickness on supply ducts and 9mm on Return Ducts with required accessories and connections with the plenum. 4 numbers return duct duct-integrated aluminium powder-coated exhaust grills to be considered	BOQ to be followed. No changes is acceptable
7	Barpeta: Technical Specification/ make	SITC of Automatic Hermetically Sealing, Sliding Doors : Metaflex /RIBBON	Requested inclusion of MPS make	BOQ to be followed. No changes is acceptable
8	Barpeta: Technical Specification/ make	SITC of HVAC SYSTEM: AHU UNIT - 3000 CFM WITH Pre & Fine FILTERS along with the connection of existing pipeline with all accesssries required. (Panel, PIBC, Temp & Pressure gauges to be considered) AIRWAVES / EDGETECH / SYSTEMAIR	Requested inclusion of MPS make	SITC of HVAC SYSTEM: AHU UNIT - 3000 CFM WITH Pre & Fine FILTERS along with the connection of existing pipeline with all accesssries required. (Panel, PIBC, Temp & Pressure gauges to be considered): AIRWAVES / EDGETECH / SYSTEMAIR/ZECO

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
9	Silchar: Technical Specification/ make	SITC of HVAC SYSTEM: AHU UNIT - 3000 CFM WITH Pre & Fine FILTERS along with the connection of existing pipeline with all accessries required. (Panel, PIBC, Temp & Pressure gauges to be considered): AIRWAVES / EDGETECH / SYSTEMAIR	Requested inclusion of ZECO make	SITC of HVAC SYSTEM: AHU UNIT - 3000 CFM WITH Pre & Fine FILTERS along with the connection of existing pipeline with all accessries required. (Panel, PIBC, Temp & Pressure gauges to be considered): AIRWAVES / EDGETECH / SYSTEMAIR/ZECO
11	Barpeta: Technical Specification/ make	SITC of Laminar Air Flow Ceiling System with Mini Pleat H-14 Grade Hepa Filters Laminar Air Flow - Spectrum/ Thermodyne /PES Hepa Filter -AAF/Mechmaark/Thermodyne/Spectrum	Requested inclusion of MPS make	Makes : Laminar Air Flow - Spectrum/ Thermodyne /PES /MPS/Modular System Hepa Filter - AAF/Mechmaark/Thermodyne/Spectrum
12	Silchar: Technical Specification/ make	SITC of Laminar Air Flow Ceiling System with Mini Pleat H-14 Grade Hepa Filters : Laminar Air Flow - Spectrum/ Thermodyne /PES Hepa Filter -AAF/Mechmaark/ Thermodyne/Spectrum	Requested inclusion of MPS make	BOQ to be followed. No change.

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
13	Technical Specification/ make	<p>SITC of Laminar Air Flow Ceiling System with Mini Pleat H-14 Grade Hepa Filters :</p> <p>The Plenum will have Unidirectional flow which is needed to guarantee a continuous and effective air quality level below the ceiling, where surgeons and patients care.</p> <p>PLENUM UNIT: The plenum structure will be made of aluminium. The complete unit shall have factory prepared fine sealing system. HEPA FILTERS: These absolute filters will be flange-type mini pleat HEPA filters of 99.995% down to 0.3 microns. The filter section is made of Hepa Filters class H14 (EN 1822 class). The plenum diffuser grills will be of stainless steel 304-grade material. (Size : 2400 x 2400)</p> <p>Make - Spectrum/ Thermodyne /PES Hepa Filter -AAF/Mechmaark/Thermodyne/Spectrum</p>	<p>The Plenum will have Unidirectional flow which is needed to guarantee a continuous and effective air quality level below the ceiling, where surgeons and patients care.</p> <p>PLENUM UNIT: The plenum structure will be made of aluminium. The complete unit shall have factory prepared fine sealing system. HEPA FILTERS: These absolute filters will be flange-type mini pleat HEPA filters of 99.995% down to 0.3 microns. The filter section is made of Hepa Filters class H14 (EN 1822 class). The plenum diffuser grills will be of stainless steel 304-grade material. (Size : 2400 x 2400)</p> <p>Kindly amend to read as "Make - Modular System/Spectrum/ Thermodyne /PES Hepa Filter - AAF/Mechmaark/Thermodyne/Spectrum"</p>	<p>Makes : Laminar Air Flow - Spectrum/ Thermodyne /PES /MPS/Modular System</p> <p>Hepa Filter - AAF/Mechmaark/Thermodyne/Spectrum</p>
14	Silchar: Technical Specification/ make	<p>SITC of LED Dimmable X-Ray (2 Plate):</p> <p>PES /Altos /Digiline</p>	Requested inclusion of MPS make	SITC of LED Dimmable X-Ray (2 Plate): PES /Altos /Digiline/MPS
15	Barpeta: Technical Specification/ make	<p>SITC of LED Dimmable X-Ray (2 Plate):</p> <p>PES /Altos /Digiline</p>	Requested inclusion of MPS make	SITC of LED Dimmable X-Ray (2 Plate): PES /Altos /Digiline/MPS

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
16	Dibrugarh: Technical Specification/ make	SITC of LED Dimmable X-Ray (2 Plate): PES /Altos /Digiline	Requested inclusion of MPS make	SITC of LED Dimmable X-Ray (2 Plate): PES /Altos /Digiline/MPS
17	Technical Specification/ make	<p>SITC of Peripheral Lights:</p> <p>IP 65 Peripheral Lights non-hygroscopic peripheral lights peripheral lights for clean room application, low power consumption with dimmer control (suitable for clean room application). The luminaries are to be provided in such a way as to achieve the light intensity of 350 Lux at 1m from the floor.</p> <p>Make - Wirpo/Philips/Syska</p>	<p>IP 65 Peripheral Lights non-hygroscopic peripheral lights peripheral lights for clean room application, low power consumption with dimmer control (suitable for clean room application). The luminaries are to be provided in such a way as to achieve the light intensity of 350 Lux at 1m from the floor.</p> <p>Kindly amend to read as "Digiline/Wirpo/Philips/Syska"</p>	<p>SITC of Peripheral Lights:</p> <p>IP 65 Peripheral Lights non-hygroscopic peripheral lights peripheral lights for clean room application, low power consumption with dimmer control (suitable for clean room application). The luminaries are to be provided in such a way as to achieve the light intensity of 350 Lux at 1m from the floor.</p> <p>Make - Wirpo/Philips/Syska/Digiline</p>
18	Dibrugarh: Technical Specification/ make	SITC of Wall mounted Surgeon Control panel Touch screen (21 inch) Type : PES /Digiline /BIOX	Requested inclusion of MPS make	SITC of Wall mounted Surgeon Control panel Touch screen (21 inch) Type : Make: Digiline /BIOX
19	Barpeta: Technical Specification/ make	SITC of Wall mounted Surgeon Control panel Touch screen(21 inch) Type : PES /Digiline /BIOX	Requested inclusion of MPS make	SITC of Wall mounted Surgeon Control panel Touch screen(21 inch) Type : Make: Digiline /BIOX
20	Silchar: Technical Specification/ make	SITC of Wall mounted Surgeon Control panel Touch screen(21 inch) Type : PES /Digiline /BIOX	Requested inclusion of MPS make	SITC of Wall mounted Surgeon Control panel Touch screen(21 inch) Type : Make: Digiline /BIOX

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
21	Barpeta: Technical Specification/ make	Supply and installation of Operating Writing List Board : PES /Altos /Digiline	Requested inclusion of MPS make	Supply and installation of Operating Writing List Board : PES /Altos /Digiline/MPS
22	Dibrugarh: Technical Specification/ make	Supply and installation of Operating Writing List Board : PES /Altos /Digiline	Requested inclusion of MPS make	Supply and installation of Operating Writing List Board : PES /Altos /Digiline/MPS
23	Criteria: 10.2	The Bidder should have an average annual turnover of Rs. 10.00 Crores or more in the last three (3) financial years (i.e., 2019-20 or 2020-21, 2021-22) duly certified by the Chartered Accountant as per the format at Format T8.	the Average Annual Turnover of the bidder is mentioned Rs. 10.00 Crore in the last three year which may please be reduced to Rs. 7.50 Crore.	The Bidder should have an average annual turnover of Rs. 3.00 Crores or more in the last three (3) financial years (i.e., 2021-22, 2022-23, 2023-24) duly certified by the Chartered Accountant as per the format at Format T8.

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
24	Criteria: 10.3	<p>The Bidder should have experience of successful execution of similar assignments/contract of value (cumulative total) not less than Rs 5.00 Crore of supply, installation and commissioning of “OTs” of any Government, PSU or Corporate Hospital during last three financial years i.e., 2019-20, 2020-2021, 2021-22. The Work Order copies in support of that in last 3 financial years to be furnished (As per Format T9). Authorized Dealer or Distributor can participate (for that Bidder need to submit the authorization from OEM for major items). Bidders need to fulfil all the eligibility criteria.</p>	<p>The successful execution value is mentioned Rs. 5.00 Crore during the last three year which may please be reduced to Rs. 1.50 Crore.</p>	<p>The Bidder should have experience of successful execution of similar assignments/contract of value (cumulative total) not less than Rs 1.50 Crore of supply, installation and commissioning of “OTs” of any Government, PSU or Corporate Hospital during last three financial years i.e., 2021-22, 2022-23, 2023-24. The Work Order copies of minimum 3 OTs of different organisations in support of that in last 3 financial years to be furnished (As per Format T9). Authorized Dealer or Distributor can participate (for that Bidder need to submit the authorization from OEM for major items). Bidders need to fulfil all the eligibility criteria.</p>

No	Tender term no and pg. no	Tender terms	Changes / amendment / clarification required	ACCF Clarification / Amendment
25	Criteria: 10.3	The Bidder should have experience of successful execution of similar assignments/contract of value (cumulative total) not less than Rs 5.00 Crore of supply, installation and commissioning of “OTs” of any Government, PSU or Corporate Hospital during last three financial years i.e., 2019-20, 2020-2021, 2021-22. The Work Order copies in support of that in last 3 financial years to be furnished (As per Format T9). Authorized Dealer or Distributor can participate (for that Bidder need to submit the authorization from OEM for major items). Bidders need to fulfil all the eligibility criteria.	Requested to modify the clause to allow bidder or the OEM to fulfill the requirement	The Bidder should have experience of successful execution of similar assignments/contract of value (cumulative total) not less than Rs 1.50 Crore of supply, installation and commissioning of “OTs” of any Government, PSU or Corporate Hospital during last three financial years i.e., 2021-22, 2022-23, 2023-24. The Work Order copies of minimum 3 OTs of different organisations in support of that in last 3 financial years to be furnished (As per Format T9). Authorized Dealer or Distributor can participate (for that Bidder need to submit the authorization from OEM for major items). Bidders need to fulfil all the eligibility criteria.
26	General Conditions	Timeline for Execution of work	On page number 2 Execution time is 90 days & on page number 3 it is 60 days therefore we request you to consider minimum 90-120 days.	Only a 60-day period will be followed, as there are no items in our BOQ that require a longer lead time

Other terms and conditions of tender remain the same.

-Sd-

AGM PROCUREMENT, ACCF